



**Applied Relay Testing Ltd**



27 COBHAM ROAD  
FERNDOWN  
DORSET ENGLAND  
BH21 7PE UK.



Tel: +44 (0) 1202 892777  
Fax: +44 (0) 1202 894268

Email: [sales@appliedrelaytesting.com](mailto:sales@appliedrelaytesting.com)  
Web site: [www.appliedrelaytesting.com](http://www.appliedrelaytesting.com)

## **Application Note AN310196 - Fast testing with the RT290 relay test system, and comparison between RT90 and RT290.**

### **Contents.**

<b>CONTENTS.....</b>	<b>1</b>
<b>INTRODUCTION.....</b>	<b>1</b>
<b>OBTAINING DEVICE TEST TIMES.....</b>	<b>2</b>
VRM (VRAMP: OPERATE AND RELEASE).....	3
CLR (COIL RESISTANCE).....	3
CTY (ADAPTOR CONTINUITY).....	3
CTR (CONTACT RESISTANCE).....	3
CRS (CONTACT RESISTANCE STABILITY).....	3
TIM (TIMING).....	3
DIO (DIODE TEST).....	3
VFUN (VFUNCTIONAL TEST).....	4
VPLS (VPULSE TEST).....	4
DYCR (DYNAMIC CR).....	4
PORT (I/O PORT UTILITY).....	4
SHRT (CONTACT SET SHORTS).....	4
IRM (IRAMP: OPERATE AND RELEASE).....	4
<b>MEASURING THE SPEED OF A TEST STEP.....</b>	<b>4</b>
<b>CALCULATING THE EXECUTION TIME OF A TEST SEQUENCE.....</b>	<b>5</b>
<b>A FAST, SIMPLE, RELAY DEVICE TEST.....</b>	<b>5</b>
<b>COMPARISON OF TEST TIMES BETWEEN RT90 AND RT290.....</b>	<b>5</b>
<b>APPENDIX 1: PRINT-OUT OF RELAY DEVICE TEST FAST.R90.....</b>	<b>7</b>

### **Introduction.**

This note discusses how to achieve the shortest possible test times for a relay device test and the typical time to be expected from a minimum device test sequence. It is based around the RT290 test system. Much of the detailed documentation is found in the application-specific manual ASY0632 which should be used in conjunction with this document.

## **Obtaining device test times.**

The manual ASY0632 includes test times for each of the device test steps as follows:

<b>Name of test type</b>	<b>Description of test.</b>	<b>Approx. time.</b>
Adaptor Continuity.	Measures and confirms correct device adaptor connection.	38ms - but see note 'CTY'
Coil Resistance.	Measures the resistance of specified coil(s).	50ms - but see note 'CLR'
Contact Resistance.	Measures the resistance of specified contacts.	60-150ms - but see note 'CTR'
Contact Resistance Stability.	Measures the delta, min, mean, max. and standard deviation of a number of contact cycles.	From 105ms - but see note 'CRS'
Timing: Operate and Release	Measures the operate and release timing of specified contacts.	100ms - but see note 'TIM'
VRamp: Operate and Release.	Measures the operate and release voltage parameters of a device.	See note 'VRM'
IRamp: Operate and Release.	Measures the operate and release current parameters of a device.	See note 'IRM'
Diode check	Confirms presence or absence of a diode across the device coil.	65ms - but see note 'DIO'
V Functional	Applies various voltage levels to a device with the option of confirming the expected contacts state.	100ms but see note 'VFUN'
V Pulse	Measures the operate and release voltage parameters of a device using a pulse-based algorithm for faster determination than ramp.	0.75s, but see note 'VPLS'
Dynamic CR	Makes a 'capture' of the CR of a selected contact as it opens or closes, producing a graph of CR against time.	Not specified (but see note 'DYCR')
I/O Port control utility	Provides control and interrogation of spare handler port lines for the control of simple external equipment during a test sequence.	20ms - but see note 'PORT'
Contact set shorts	Detects shorts between contact sets.	25ms - but see note 'SHRT'

### **VRM (VRamp: Operate and Release).**

For this test programmed for a 12V device, operate and release step sizes of 0.12V (i.e. 1% of nominal voltage), 10ms settling time and with the operate ramp starting at 0V and release ramp starting at nominal voltage, this test takes 1.44s testing a monostable 4pc/o device on all contacts.

This is very close to the theoretical time for this test, and this actual v theoretical performance is maintained for settling times down to around 1ms.

Add a further time for any initial pulse if required, or if testing bistable relays - see test diagram.

Note that these test settings are pessimistic, i.e. the operate and release ramps can easily be started 'later', and the step size possibly increased. In any case, the test execution time is generally close to  $(N * S)$  where 'N' is the number of total ramp steps required, and 'S' is the specified settling time.

### **CLR (Coil Resistance).**

Typically 50ms including a programmed 10ms settling time.

### **CTY (Adaptor continuity).**

Typically 38ms testing a monostable, 4pc/o device on all contacts, remove 3ms if testing 2pc/o.

### **CTR (Contact Resistance).**

Between 60ms and 150ms depending on precision, based on a 4pc/o monostable device tested on all normally closed contacts. For normally open contacts, add twice the device settling time programmed.

### **CRS (Contact Resistance Stability).**

Typically as follows:

For 2 cycles, 480ms at 'best stability'.

For 1 cycle, 250ms at 'best stability'.

For 1 cycle, 105ms at 'best speed'.

40ms /200Hz precision.

All measurements made testing a 4pc/o monostable device on all contacts.

### **TIM (Timing).**

For this test programmed for a 12V device, test duration 20ms, this test takes 100ms testing a monostable 4pc/o device on all contacts with a maximum 15ms test limit.

Note that a further time should be added if an initial pulse is used or if testing bistable devices - see the test diagram.

### **DIO (Diode test).**

This test takes 65ms.

### **VFUN (Vfunctional test).**

For this test programmed for 5 levels and 15ms settling times, this test takes approx. 100ms testing a monostable 4pc/o device on all contacts.

This is very close to the theoretical time for this test, and this actual v theoretical performance is maintained for settling times down to around 1ms.

Note that a further time should be added if an initial pulse is used or if testing bistable devices - see the test diagram.

### **VPLS (VPulse test).**

This test takes 0.75s testing a 4pc/o monostable device with 15ms settling times.

This is very close to the theoretical time for this test, and this actual v theoretical performance is maintained for settling times down to around 1ms.

### **DYCR (Dynamic CR).**

Execution for this test is not specified.

### **PORT (I/O Port utility).**

Typically 20ms, but note that time spent waiting during the programmed wait times must be added.

### **SHRT (Contact set shorts).**

Typically 25ms testing a 4pc/o monostable device on all contact sets.

### **IRM (IRamp: Operate and Release).**

For this test programmed for a 25mA device, operate and release step sizes of 0.25mA (i.e. 1% of nominal current), 10ms settling time and with the operate ramp starting at 0mA and release ramp starting at nominal current, this test takes 1.44s testing a monostable 4pc/o device on all contacts.

This is very close to the theoretical time for this test, and this actual v theoretical performance is maintained for settling times down to around 1ms.

Add a further time for any initial pulse if required, or if testing bistable relays - see test diagram.

Note that these test settings are pessimistic, i.e. the operate and release ramps can easily be started 'later', and the step size possibly increased. In any case, the test execution time is generally close to  $(N * S)$  where 'N' is the number of total ramp steps required, and 'S' is the specified settling time.

### **Measuring the speed of a test step.**

The typical execution times for each test type are shown in the data for each test type. The times are measured by observing the BUSY output of the RT290 when only the specified test step is executed using 'Run', 'Next Test'. When observing this BUSY active time, the adaptor operate and release delays will be included in your observed time. These delays are specified in the BIOSCFG.INI file and have been removed from the quoted times, i.e. the published times are close to that of the actual test step. Where the test shows 'NA', the time has either not been measured, or is short enough to be neglected.

### **Calculating the execution time of a test sequence.**

Use the equation:

$$A_o + T_1 + T_2 + T_3 + A_r$$

to determine the length of a test sequence, where  $A_o$  and  $A_r$  are the operate and release delays for the adaptor respectively (these are programmed in the BIOSCFG.INI file with defaults of 100ms) and  $T_1..T_n$  are the specified 'Speed of execution' times quoted in the test type documentation.

Note that this will be an approximation, and that there will be variations due to adaptor re-tries, any multi-tasking on the PC etc.

### **A fast, simple, relay device test.**

AS an example of a fast, simple, relay device test, the listing 'FAST.R90' in appendix 1 shows a device test based on the following tests:

- Adaptor check.
- Coil Resistance.
- Timing.
- V Functional.
- Contact Resistance Stability.

These 5 tests make a basic check on all parameters of the device. The part is a 4-pole changeover device, nominal 12V, 470R coil, and most times are based on a 15ms test limit.

This complete test executes in 340ms on the RT290, and ignoring the default 100ms adaptor operate and release delays.

If required, the 'Contact Resistance' tests can be substituted for the 'Contact Resistance Stability' test shown - there will be little change to the overall timing. The CR stability test was chosen because both NO and NC results are available in one test step, and statistical values are available if the number of measurements is set to greater than 1.

In many cases, the test can be further optimised, particularly by reducing the settling times shown. The CR measurement is made at a 'best speed' precision which has been found to be close to the full 'best stability' precision yet with a worthwhile time saving.

### **Comparison of test times between RT90 and RT290.**

For Users of the RT90, this section reproduces the timing table above but with RT90 test times compared.

As an additional comparison, the listed file 'FAST.R90' executes on the RT90 at 860ms and on the RT290 at 340ms.

For more details on the RT90 performance, view the document AN180995 'Fast testing with the RT90'.

<b>Name of test type</b>	<b>Description of test.</b>	<b>RT90 time</b>	<b>RT290 time</b>
Adaptor Continuity.	Measures and confirms correct device adaptor connection.	180ms	38ms
Coil Resistance.	Measures the resistance of specified coil(s).	80ms	50ms
Contact Resistance.	Measures the resistance of specified contacts.	110ms-220ms	60-150ms
Contact Resistance Stability.	Measures the delta, min, mean, max. and standard deviation of a number of contact cycles.	260ms/cycle - 520ms/cycle	105ms - 250ms
Timing: Operate and Release	Measures the operate and release timing of specified contacts.	100ms	100ms
VRamp: Operate and Release.	Measures the operate and release voltage parameters of a device.	60ms + As theoretical down to approx. 5ms settling	60ms + As theoretical down to 1ms settling
IRamp: Operate and Release.	Measures the operate and release current parameters of a device.	As for VRamp	As for VRamp
Diode check	Confirms presence or absence of a diode across the device coil.	110ms	65ms
V Functional	Applies various voltage levels to a device with the option of confirming the expected contacts state.	105ms	100ms
V Pulse	Measures the operate and release voltage parameters of a device using a pulse-based algorithm for faster determination than ramp.	60ms + As theoretical down to approx. 5ms settling	60ms + As theoretical down to 1ms settling
Dynamic CR	Makes a 'capture' of the CR of a selected contact as it opens or closes, producing a graph of CR against time.	Not specified	Not specified
I/O Port control utility	Provides control and interrogation of spare handler port lines for the control of simple external equipment during a test sequence.	20ms	20ms
Contact set shorts	Detects shorts between contact sets.	60ms	25ms

## Appendix 1: Print-out of relay device test FAST.R90.

```
[ ----- ]
[ Printed from   : RT290 SOFTWARE, V1.00c 27/12/95 ]
[ Description    : Immediate print of test sequence ]
[ Date and time  : 11:26:46, Wednesday, 31st January 1996 ]
[ Test file path : 'C:\RT290\FAST.R90' ]
[ File reference : 'A demonstration of a fast 4pc/o relay - 340ms RT290' ]
[ ----- ]
```

### 1[-] "Batch definition"

#### CONDITION LIST

```
C1 Part Number           = No part number
C2 Device Type           = No Device Type
C4 Operator              = No operator
C5 Batch                 = No batch
C6 Lot                   = No lot
C7 Sample Plan           = No sample plan
C20 Device routing       = None specified
```

#### RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

#### RESULT LIST

```
DATALOG True [Always]
PRINT   True [Always]
HANDLER BIN Fail: 0, Pass: 0
JUMP    False [Never], to step <End of program>
```

### 2[-] "Adaptor continuity"

#### CONDITION LIST

```
C121 Device coil format      = As monostable A+
C101 Device contact format   = 4PCO (Sets 1..4)
C102 Contacts to test        = C,C,C,C,X,X
C416 Max adaptor resistance   = 5.00 R
C417 Max adaptor retries     = 3
```

#### RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

#### RESULT LIST

```
DATALOG True [Always]
PRINT   True [Always]
HANDLER BIN Fail: 0, Pass: 0
JUMP    False [Never], to step <End of program>
```

### 3[-] "Coil resistance"

#### CONDITION LIST

```
C122 Coil to measure         = Coil-A (Monostable)
C201 # Voltage default       = 12.00 V
C301 # Current default       = 0.000 mA
C401 # RCoil default         = 0.000 kR
C124 Device coil suppression = Network #0
C123 Coil polarity           = Normal ( high is +ve)
C210 Voltage to apply        = 6.00 V
C310 Current to apply        = 100.000 mA
C510 Settling time           = 10.000 ms
C415 Max Rcoil pass limit    [414/ ] = 100.000 kR
C414 Min Rcoil pass limit    [ /415] = 10.000 R
C601 Use temperature probe    = No
C602 Temperature coeff of wire = 0.400 %/Dg
C603 Refer back to temperature = 20.0 DegC
C604 Non-probe correction factor = 1.000
```

#### RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

#### RESULT LIST

```
DATALOG True [Always]
PRINT   True [Always]
HANDLER BIN Fail: 0, Pass: 0
JUMP    False [Never], to step <End of program>
```

-----  
 4[-] "Timing: Operate & Release"

CONDITION LIST

C121	Device coil format	=	As monostable A+
C101	Device contact format	=	4PCO (Sets 1..4)
C102	Contacts to test	=	C,C,C,C,X,X
C201	# Voltage default	=	12.00 V
C301	# Current default	=	0.000 mA
C401	# RCoil default	=	0.000 kR
C501	# TStable default	=	15.000 ms
C124	Device coil suppression	=	Network #0
C250	Initial voltage	=	0.00 V
C313	Initial current	=	100.000 mA
C510	Settling time	=	15.000 ms
C529	System timebase	=	1us (1MHz)
C700	Number of measurements	=	1
C701	Operate segment mode	=	Normal
C221	Operate applied voltage	=	12.00 V
C311	Operate applied current	=	100.000 mA
C702	Release segment mode	=	Normal
C241	Release applied voltage	=	12.00 V
C312	Release applied current	=	100.000 mA
C520	Opr: Min T stable	[ /521]	= 0.000 ms
C521	Opr: max T stable	[520/ ]	= 15.000 ms
C524	Opr: Min T transfer	[ /525]	= 0.000 ms
C525	Opr: max T transfer	[524/521]	= 15.000 ms
C512	Opr: Min T action	[ /513]	= 0.000 ms
C513	Opr: max T action	[512/ ]	= 15.000 ms
C514	Opr: Max T bounce		= 3.750 ms
C515	Opr: Max num bounces		= 1000
C522	Rel: Min T stable	[ /523]	= 0.000 ms
C523	Rel: max T stable	[522/ ]	= 15.000 ms
C526	Rel: Min T transfer	[ /527]	= 0.000 ms
C527	Rel: max T transfer	[526/523]	= 15.000 ms
C516	Rel: Min T action	[ /517]	= 0.000 ms
C517	Rel: max T action	[516/ ]	= 15.000 ms
C518	Rel: Max T bounce		= 3.750 ms
C519	Rel: Max num bounces		= 1000

RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

RESULT LIST

DATALOG True [Always]  
 PRINT True [Always]  
 HANDLER BIN Fail: 0, Pass: 0  
 JUMP False [Never], to step <End of program>

-----  
 5[-] "V Functional"

CONDITION LIST

C121	Device coil format	=	As monostable A+
C101	Device contact format	=	4PCO (Sets 1..4)
C102	Contacts to test	=	C,C,C,C,X,X
C201	# Voltage default	=	12.00 V
C301	# Current default	=	0.000 mA
C401	# RCoil default	=	0.000 kR
C501	# TStable default	=	15.000 ms
C124	Device coil suppression	=	Network #0
C510	Settling time	=	15.000 ms
C310	Current to apply	=	100.000 mA
C1011	Level mode 1	=	OxR (App OP, exp RL).
C1012	V Applied Level 1	=	2.40 V
C1013	V Step to Level 1	=	0.00 V
C1014	T Step to Level 1	=	0.000 ms
C1021	Level mode 2	=	OxO (App OP, exp OP).
C1022	V Applied Level 2	=	9.60 V
C1023	V Step to Level 2	=	0.00 V
C1024	T Step to Level 2	=	0.000 ms
C1031	Level mode 3	=	O (App OP only).
C1032	V Applied Level 3	=	12.00 V
C1033	V Step to Level 3	=	0.00 V
C1034	T Step to Level 3	=	0.000 ms
C1041	Level mode 4	=	RxO (App RL, exp OP).
C1042	V Applied Level 4	=	8.40 V
C1043	V Step to Level 4	=	0.00 V

```

C1044 T Step to Level 4 = 0.000 ms
C1051 Level mode 5 = RxR (App RL, exp RL).
C1052 V Applied Level 5 = 1.80 V
C1053 V Step to Level 5 = 0.00 V
C1054 T Step to Level 5 = 0.000 ms
C1061 Level mode 6 = End.
C1062 V Applied Level 6 = 0.00 V
C1063 V Step to Level 6 = 0.00 V
C1064 T Step to Level 6 = 0.000 ms
C1071 Level mode 7 = End.
C1072 V Applied Level 7 = 0.00 V
C1073 V Step to Level 7 = 0.00 V
C1074 T Step to Level 7 = 0.000 ms
C1081 Level mode 8 = End.
C1082 V Applied Level 8 = 0.00 V
C1083 V Step to Level 8 = 0.00 V
C1084 T Step to Level 8 = 0.000 ms
C1091 Level mode 9 = End.
C1092 V Applied Level 9 = 0.00 V
C1093 V Step to Level 9 = 0.00 V
C1094 T Step to Level 9 = 0.000 ms
C1101 Level mode 10 = End.
C1102 V Applied Level 10 = 0.00 V
C1103 V Step to Level 10 = 0.00 V
C1104 T Step to Level 10 = 0.000 ms

```

RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

RESULT LIST

DATALOG True [Always]

PRINT False [Never]

HANDLER BIN Fail: 0, Pass: 0

JUMP False [Never], to step <End of program>

6[-] "CR stability"

CONDITION LIST

```

C121 Device coil format = As monostable A+
C101 Device contact format = 4PCO (Sets 1..4)
C102 Contacts to test = C,C,C,C,X,X
C201 # Voltage default = 0.00 V
C301 # Current default = 0.000 mA
C402 # RContact default = 0.0000 R
C401 # RCoil default = 0.000 kR
C501 # TStable default = 0.000 ms
C124 Device coil suppression = Network #0
C103 Contact side to measure = Normally open
C212 VClamp = 50 mV
C104 Contact load = CA0 (as gen and clamp)
C210 Voltage to apply = 12.00 V
C310 Current to apply = 100.000 mA
C510 Settling time = 15.000 ms
C410 CR Measurement range = 1R, AC, 10mV, 10mA
C411 CR measurement precision = 4 (best speed)
C700 Number of measurements = 1
C420 RMin limit: Min RContact [ /421] = 0.0000 R
C421 RMax limit: Min RContact [420/ ] = 0.1000 R
C422 RMin limit: Max RContact [ /423] = 0.0000 R
C423 RMax limit: Max RContact [422/ ] = 0.1000 R
C428 RMin limit: Delta RContact [ /429] = 0.0000 R
C429 RMax limit: Delta RContact [428/ ] = 0.0100 R
C424 RMin limit: Mean RContact [ /425] = 0.0000 R
C425 RMax limit: Mean RContact [424/ ] = 0.1000 R
C426 RMin limit: StDev RContact [ /427] = 0.0000 R
C427 RMax limit: StDev RContact [426/ ] = 0.0100 R

```

RESULT SUMMARY

TOTALS THIS STEP 0% (0/0)

RESULT LIST

DATALOG True [Always]

PRINT False [Never]

HANDLER BIN Fail: 0, Pass: 0

JUMP False [Never], to step <End of program>

End of listing.